



Certificate of Compliance

Certificate: 70043912

Master Contract: 261002

Project: 70161379

Date Issued: 2017-11-21

Issued to: Hoymiles Converter Technology Co. , Ltd.
No.18 Kangjing Road,
Hangzhou, Zhejiang 310015
CHINA
Attention: Yi Zhao

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Michael Tong*
Michael Tong

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Utility Interactive Inverter, Model MI-500, MI-500T, MI-600 and MI-600T, rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-01

- General Use Power Supplies

*UL Std. No. 1741-Second Edition

- Inverters, Converters, Controllers and Interconnection System

Equipment for Use With Distributed Energy Resources (January 28, 2010)

*Note: Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of ANSI/IEEE 1547 (R2008) and ANSI/IEEE 1547.1 (R2011).



Supplement to Certificate of Compliance

Certificate: 70043912

Master Contract: 261002

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70161379	2017-11-21	Update report 70043192 to including alternate components and change MPPT voltage range.
70043912	2015-10-28	Utility Interactive Inverter, Model MI-500 and MI-600.(C/US)