



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA200317

Date of Issue: 4 March 2020

Regulatory Definition: Non-Prescribed

Product Description: Grid-tied Microinverter

Additional Models	Trade Name	Rating
HM-300	hoymiles	Input: Peak Power Voltage Range: 29-48Vdc, Max 60Vdc, Max 11.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.5A, Max 300VA
HM-300T	hoymiles	Input: Peak Power Voltage Range: 29-48Vdc, Max 60Vdc, Max 11.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.5A, Max 300VA
HM-300A	hoymiles	Input: Peak Power Voltage Range: 29-48Vdc, Max 60Vdc, Max 11.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.5A, Max 300VA
HM-250	hoymiles	Input: Peak Power Voltage Range: 27-48Vdc, Max 60Vdc, Max 10.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.25A, Max 250VA
HM-250T	hoymiles	Input: Peak Power Voltage Range: 27-48Vdc, Max 60Vdc, Max 10.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.25A, Max 250VA
HM-250A	hoymiles	Input: Peak Power Voltage Range: 27-48Vdc, Max 60Vdc, Max 10.5A, Isc: 15A Output: 220/230/240V~ 50/60Hz, Max 1.25A, Max 250VA

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 05-03-20 200317/3a
Correction to Rating