



Microinverter Datasheet

HM-600
HM-700
HM-800

Description

Hoymiles 2-in-1 microinverter can connect up to 2 panels at once and maximize the PV production of your installation.

All of the three models listed are equipped with reactive power control and can meet the requirements of EN 50549-1:2019, VDE-AR-N 4105:2018, UL 1741, etc. They're also designed with external antenna for stronger communication with Hoymiles gateway DTU.

Features

01

Easy installation, just plug and play

03

External antenna for stronger communication with DTU

02

With Reactive Power Control, compliant with VDE-AR-N 4105: 2018 & EN 50549-1: 2019

04

High reliability: IP67 (NEMA 6) enclosure, 6000 V surge protection

Technical Specifications

Model	HM-600	HM-700	HM-800
Input Data (DC)			
Commonly used module power (W)	240 to 405+	280 to 470+	320 to 540+
Maximum input voltage (V)	60		
MPPT voltage range (V)	16-60		
Start-up voltage (V)	22		
Maximum input current (A)	2 × 11.5	2 × 11.5	2 × 12.5
Maximum input short circuit current (A)	2 × 15		
Output Data (AC)			
Rated output power (VA)	600	700	800
Rated output current (A)	2.61	3.04	3.48
Nominal output voltage range (V) ¹	230/180-275		
Nominal frequency/range (Hz) ¹	50/45-55 or 60/55-65		
Power factor (adjustable)	> 0.99 default 0.8 leading...0.8 lagging		
Total harmonic distortion	< 3%		
Maximum units per branch ²	8	7	6
Efficiency			
CEC peak efficiency	96.70%		
CEC weighted efficiency	96.50%		
Nominal MPPT efficiency	99.80%		
Nighttime power consumption (mW)	< 50		
Mechanical Data			
Ambient temperature range (°C)	-40 to +65		
Dimensions (W × H × D mm)	250 × 170 × 28		
Weight (kg)	3.0		
Enclosure rating	Outdoor IP67 (NEMA 6)		
Cooling	Natural convection (no fans)		
Features			
Communication	2.4 GHz Proprietary RF (Nordic)		
Type of isolation	Galvanically Isolated HF Transformer		
Monitoring	S-Miles Cloud ³		
Compliance	VDE-AR-N 4105: 2018, EN 50549-1: 2019, VFR 2019, IEC/EN 62109-1/-2, IEC/EN 61000-6-1/-2/-3/-4, IEC/EN 61000-3-2/-3		

*1 Nominal voltage/frequency range can vary depending on local requirements.

*2 Refer to local requirements for exact number of microinverters per branch.

*3 Hoymiles Monitoring System.